

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Letter No. 293

Dated: 17/06/2026

It is certified that an inspection team headed by Zeeshan Haider (Assistant Engineer) from P.H.E.D. Supaul inspected the RADHE SHYAM PUBLIC SCHOOL, SISAUNI ROAD, SUPAUL - Bihar 852131 on 14.06.2026 and found that the RADHE SHYAM PUBLIC SCHOOL has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State U.T Govt.

The above is valid for a period of 01 Year.

Signature with Seal:

Name :- Zeeshan Haider

Designation:- Assistant Engineer

17/06/26
S.D.O
P.H. Sub. Division
Supaul

To,

RADHE SHYAM PUBLIC SCHOOL,
Sisauni Road, Supaul 852131 (Bihar)

Government of Bihar
PUBLIC HEALTH ENGINEERING DEPARTMENT

P. H. Division, Supaul

WATER QUALITY TESTING REPORT

**Location of Source :- Radhe Shyam Public School, Sisauni Road ,
Supaul-852131**

Sample Given By:- School Staff

Type of Sample:- Treated Water

Date of Sampling :- 13/06/2026

Date of Testing :- 16/06/2026

Analysis Result				
Sl. No.	PARTICULARS	PERMISSIBLE LIMIT	Obsrvation	Remarks
1	pH	6.5-8.5	7.04	
2	Turbidity	1-5 NTU	0.1	
3	Conductivity		140	
4	TDS	500-2000 mg/L	86	
5	Total Hardness	300-600 mg/L	65.28	
6	Iron	1.0 - NR mg/L	0.46	
7	Bacteriological Test By H2S strip vial	Not Found	Note Found	

Note:- NR= No Relaxation


16/06/26
Chemist
DLWTL, Supaul


16/06/26
Assistant Engineer
P.H. Sub Division, Supaul